



NORTH CITY
Water District

1519 NE 177th St. • P.O. Box 55367 • Shoreline, WA 98155 • Phone: 206.362.8100 • Fax: 206.361.0629

Commissioners:

Ron Ricker

Charlotte Haines

Larry Schoonmaker

District Manager:

Diane Pottinger, P.E.

June 20, 2017

Upright Construction
18827 53RD AVE NE
Lake Forest Park, WA 98155



Re: Fire Flow Analysis Task No. 1540
3030 NE 200th ST
Lake Forest Park, WA 98155

Dear Brian Highberger,

Attached is the Fire Flow Analysis requested for your project. Below are the requirements based on the District's design criteria.

Fire Flow Available per Attached	1545 gpm
Fire Flow Required Per NCWD Water System Plan	1000 gpm
Water System Improvements Required to Complete Project	No
Water System Extension Required	No
Analysis Expiration Date	06/20/2018

Note: North City Water District requires the property owner to upgrade the existing water service to meet the current District Standards. Fire Service may be required.

Should you have any question concerning the above, please feel free to contact me at (206) 362-8100.

Sincerely,

Denny Clouse
Operations Manager